Tenter Weg 2-8 | 42897 Remscheid | GERMANY Phone +49 2191 9672-0 | Fax +49 2191 9672-40 www.senseca.com | info@senseca.com | WEEE Reg. No. DE 93889386

# senseca

### **Product Information**

# LABO-HD2K-I/U/F/C

# Flow Transmitter/Switch LABO-HD2K-I / U / F / C



- 4..20 mA output linearised
- 0..10V output linearised
- Frequency output proportional, linear
- Programmable through teaching
- LED for status display
- All metal housing
- Fully potted IP 67
- All parameters programmable via USB interface ECI-1

#### **Characteristics**

Mechanical flow switch, for oil, with spring-supported piston and magnetic triggering of Hall sensors. Robust construction in brass or stainless steel.

The LABO electronics make various output signals available:

- Analog signal 0/4...20 mA (LABO-HD2K-...I)
- Analog signal 0/2..10 V (LABO-HD2K-...U)
- Frequency signal (LABO-HD2K-...F) or
- A value signal Pulse / x Litres (LABÓ-HD2K-...C)

A model with switching output is also available.

If desired, the range end value can be set to the currently existing flow using "teaching".

#### **Technical data**

Canaar	analag Hall sansara				
Sensor	analog Hall sensors				
Nominal width	DN 825				
Process connection	female thread G <sup>1</sup> / <sub>4</sub> G 1				
Metering range	0.560 l/min for details see				
Pressure loss	1.13.5 bar at Q <sub>max</sub> see table "Ranges"				
Q <sub>max</sub> .	To 80 I/min				
Tolerance	±3 % of full scale valu				
Pressure	PN 200 bar, optionally	PN 500 bar			
resistance	22 25 22 11 11	22 122 22			
Media temperature	-20+85 °C optionally	-20+120 °C			
Ambient	-20+70 °C				
temperature	-20+70 C				
Media	oils				
Wiring	see section "Wiring"				
Supply voltage	1830 V DC				
Power	< 1 W				
consumption					
Outputs	LABOI:	_			
	current output 420 m				
	(alternatively 020 m/ max. load 500 Ohm	A)			
	LABOU:				
	voltage output 010 V				
	(alternatively 210 V)				
	load min. 1 kOhm				
	LABOF:				
	frequency output				
	transistor output "push-pull" (resistant to short circuits, and reversal				
	polarity protected) lout				
	selectable frequency, max. 2 kHz				
	LABOC:				
	Transistor output "Push-Pull"				
	I <sub>out</sub> = 100 mA max.				
	Pulse width 50 ms Pulse/Value is to be specified when				
	ordering	Journal Wildin			
Display	yellow LED				
	(On = Normal / Off = A				
	rapid flashing = Progra	amming)			
Ingress protection	IP 67	t = 1 M4 O = 4 . 4 l =			
Electrical connection	for round plug connector M12x1, 4-pole				
Materials	Brass construction:	Stainless steel			
medium-contact	CW614N nickelled,	construction: 1.4571,			
	CW614N, 1.4310,	1.4404, 1.4310, hard			
	hard ferrite, NBR	ferrite PTFE-coated,			
Non modition	FKM				
Non-medium- contact materials	CW614N nickelled				
Weight	see table "Dimensions and weights"				
Conformity	CE				
Installation	Standard: horizontal	inwards flow; other			
location	installation positions are possible; the				
	installation position affects the metering and				
	switching range.				

1

Tenter Weg 2-8 | 42897 Remscheid | GERMANY Phone +49 2191 9672-0 | Fax +49 2191 9672-40 www.senseca.com | info@senseca.com | WEEE Reg. No. DE 93889386



# LABO-HD2K-I/U/F/C


# **Product Information**


# Signal output curves

Value x = Begin of the specified range = not specified range


Current output

Voltage output





Frequency output



 $f_{\mbox{\scriptsize max}}$  selectable in the range of up to 2000 Hz

Other characters on request.

#### Ranges


Details in the table apply to horizontal inwards flow with increasing flow rate.

#### Viscosity compensated type LABO-HD2K

Metering range I/min oil	<b>Q</b> <sub>max.</sub> recommended	Pressure loss bar at Q <sub>max.</sub> oil mm²/s			Viscosity stability		
30330 mm²/s		30	60	100	205	330	±8 %, min.
0.5 - 8	12	1.1	1.4	1.6	2.8	3.5	±0.3 l/min
1.5 - 15	22	2.2	2.3	2.4			±0.5 l/min
2.5 - 25	35	1.9	2.0	2.1	2.3	2.9	±0.8 l/min
6.0 - 40	60					2.6	±2.7 l/min
12.0 - 60	80	2.1	2.3	2.4	2.6	2.8	±3.0 l/min

Special ranges are available.

# Wiring




Connection example: PNP NPN



# **Dimensions and weights**

Including LABO electronics

	G	Types	SW	Х	Weight kg
Brass	G 1/4	008GM	40	15	1.5
	G 3/8	010GM			
	G <sup>1</sup> / <sub>2</sub>	015GM			1.4
	G 3/4	020GM		18	
	G 1	025GM			1.3
Stainless	G 1/4	008GK	41	15	1.5
steel	G 3/8	010GK			
	G 1/2	015GK			1.4
	G 3/4	020GK		18	
	G 1	025GK			1.3



Tenter Weg 2-8 | 42897 Remscheid | GERMANY Phone +49 2191 9672-0 | Fax +49 2191 9672-40 www.senseca.com | info@senseca.com | WEEE Reg. No. DE 93889386

# senseca

# **Product Information**

# LABO-HD2K-I/U/F/C

#### Handling and operation

#### Note

The metering range end value can be programmed by the user via "teaching". Requirement for programmability must be stated when ordering, otherwise the device cannot be programmed. The ECI-1 device configurator with associated software is available as a convenient option for programming all parameters by PC, and for adjustment.

The teaching option is not available for LABO-HD2K-C.

- Include straight calming section of 5 x DN in inlet and outlet.
- Include a filter if the media are dirty (use magnetic filter for ferritic components)
- In case of unfavourable pressure conditions, for example at atmospheric pressure, may occur cavitation.

#### **Programming**

The teaching process can be carried out by the user as follows:

- The flow rate to be set is applied to the device.
- Apply an impulse of at least 0.5 seconds and max. 2 seconds duration to pin 2 (e.g. via a bridge to the supply voltage or a pulse from the PLC), in order to accept the measured value.
- When teaching has been successfully completed, pin 2 should be connected to 0 V, so as to prevent unintended programming.

The devices have a yellow LED which flashes during the programming pulse. During operation, the LED serves as a display for operating voltage (for analog output) or of switching status (for frequency or pulse output).

To avoid the need to transit to an undesired operating status for the purpose of teaching, the device can be provided ex-works with a teach-offset. The teach-offset value is added to the currently measured value before saving. The offset value can be positive or negative.

Example: The end of the metering range should be set to 80 %. However, only 60 % can be achieved without problem. In this case, the device would be ordered with a "teach-offset" of +20°%.. At a flow rate of 60 % in the process, teaching would then store a value of 80 %.

There are many more parameters which can be programmed by the ECI-1 device configurator if necessary.

# **Ordering code**

The basic device is ordered e.g. HD2K-015GM005E with electronics e.g. LABO-HD2K-INS

HD2K -		2. <b>G</b>	3.	4.	5. <b>E</b>
	6.	7.	8.	9.	
LABO-HD2K -			S		

1.	Nominal	width	
	800	DN 8 - G <sup>1</sup> / <sub>4</sub>	
	010	DN 10 - G 3/8	
	015	DN 15 - G <sup>1</sup> / <sub>2</sub>	
	020	DN 20 - G 3/4	
	025	DN 25 - G 1	
2.	Process	connection	
	G	female thread	
3.	Connecti	on material	
	M	brass	
	K	stainless steel	
4.		etering range oil 30330 mm²/s ontal inwards flow	
	008	0.5 - 8 l/min	
	015	1.5 - 15 l/min	
	025	2.5 - 25 l/min	
	040	6.0 - 40 l/min	
	060	12.0 - 60 l/min	
5.	Connection for		
	E	electronics	
6.	Analog o		
	1	current output 420 mA	
	U	voltage output 010 V	
	F	frequency output	
_	С	pulse output	
7.	Programming (a to a t		
	N	cannot be programmed (no teaching)	
_		full scale value can be programmed	
8.		connection	
_	S	for round plug connector M12x1, 4-pole	
9.	Optional		
	D 0	medium temperature up to 120 °C (with spacers)	

#### Required ordering information

For LABO-HD2K-F: Output frequency at full scale Maximum value: 2000 Hz	Hz
For LABO-HD2K-C: The volume must be specified for the	
(with numerical value and unit) which wil se. Volume per pulse (numerical value)	Il correspond to one pul-
Volume per pulse (unit)	

Tenter Weg 2-8 | 42897 Remscheid | GERMANY Phone +49 2191 9672-0 | Fax +49 2191 9672-40 www.senseca.com | info@senseca.com | WEEE Reg. No. DE 93889386

# senseca

# **Product Information**

LABO-HD2K-I/U/F/C

LABC	options
------	---------

Special range for analog output: <= Metering range	l/min
(Standard=Metering range)	
Special range for frequency output:	l/min
<= Metering range (Standard=Metering range)	
Power-On delay period (099 s)	s
(time after applying power during which the outputs are not activated or set to defined values)	
<b>Teach-offset</b> (in percent of the metering range) Standard = 0 %	<u></u> %
HD2K ontions	

#### HD2K options

Special values

Further options available on request.

#### **Accessories**

- Cable/round plug connector (KB...) see additional information "Accessories" Converter OMNI-TA
- Device configurator ECI-1